

# Maintenance Checking

Recommended Maintenance Checking Procedure for Ecoglo Evacuation Route Products:

## 6 Monthly Maintenance Check

COMPLETED

- There has been no change to the configuration of the building which renders the marked escape route unusable.
- All signs are still configured as at installation and there is no material damage to any of the products.
- All products are clean from general dust build up and any other specific obscuring deposits.
- All products are clearly visible and have not been covered up by carpet or other materials.
- All products mark a clear path and have not been obstructed by physical hazards such as trolleys, machinery, partitions, etc.
- All lights checked that the positions have not altered from design.
- All lights are in working order and clean.
- All automated lighting control systems are operational as per design.

  
VISIBLY BETTER

**Ecoglo Australia**

Phone: +61 3 8691 5288  
Email: [Australia@ecoglo.com](mailto:Australia@ecoglo.com)

[www.ecoglo.com.au](http://www.ecoglo.com.au)