

F8/AS1 Compliance Checklist for Signs Installed Outdoors

Ecoglo S20 signs meet the requirements of F8/AS1 because:

- The building is classified as Risk Group C* (requiring the signs to remain visible for 30 minutes after normal lighting fails).
- The sign is installed outdoors, and the maximum distance it needs to be visible from is half the rated distance for the sign, therefore no artificial lighting is required to keep it charged.
- The attached plan shows:
 - The location of each sign and its Ecoglo product code.

* NZBC F6 definition for Risk Group C: a building with an evacuation time of less than 30 minutes, an occupant load no more than 1000, and whose occupants are not to remain in the building during an emergency.



Ecoglo International Limited

PO Box 7698, Sydenham 8240,
77 Kingsley Street, Sydenham 8023
Christchurch
New Zealand

Phone: 03 348 3781

Fax: 03 343 6821

Email: info@ecoglo.com

www.ecoglo.co.nz

Product luminance test reports, data sheets, installation instructions, and Ecoglo's recommended maintenance/checking procedures can be found on the Ecoglo website: www.ecoglo.co.nz