

F8/AS1 Maintenance Checking

Recommended Maintenance Checking Procedure for Ecoglo Hybrid signs:

Monthly Maintenance Check *(to be carried out by the Owner or their appointed agent)*

COMPLETED



- ☐ All signs are still configured as at installation and there is no material damage to any of these products.
- ☐ All signs are clean from general dust build up and any other specific obscuring deposits.
- ☐ All signs are clearly visible and have not been covered up.
- ☐ All signs are still illuminated.

Annual Inspection *(to be carried out by an IQP)*

COMPLETED



- ☐ All signs are still configured as at installation and there is no material damage to any of these products.
- ☐ All signs are clean from general dust build up and any other specific obscuring deposits.
- ☐ All signs are clearly visible and have not been covered up.
- ☐ All signs are still illuminated



VISIBLY BETTER

Ecoglo International Limited

PO Box 7698, Sydenham 8240, 77 Kingsley Street, Sydenham 8023
Christchurch New Zealand

Phone: 03 348 3781 • Fax: 03 343 6821 • Email: info@ecoglo.com • www.ecoglo.co.nz